



Rohrsysteme

CASAFLEX - Cev za daljinsko ogrevanje

Padec tlaka DN 20 - DN 100

CFL
5.210

01.04.2003

Voda, srednja temperatura 80 °C

$$\dot{m} \approx \frac{Q \cdot 860}{\Delta T}$$

\dot{m} = masni pretok v kg/h

Q = količina toplote v kW

ΔT = temperaturna razlika (dovodni/povratni tok) v °C

